

GW 136-4.8MW

**PMDD Smart Wind Turbine** 

## **GW 136-4.8MW**

## **PMDD Smart Wind Turbine**

MW IEC m/s m/s m/s	4.8 II B 2.5
m/s m/s	2.5
m/s	
	12.5
m/s	
	26
Year	≥ 20
$^{\circ}$	-30℃ ~ +45℃
$^{\circ}$	-40℃ ~ +50℃
m	136
m <sup>2</sup>	14526
\	Permanent magnet synchronous generator
V	740
\	Full power converter
\	Capacitive 0.9 - inductive 0.9
	©

Rated output voltage	V	690
Brake system		
Aerodynamic brake system	\	Aerodynamic brake via feathering
Mechanical brake system	\	Generator hydraulic brake (for maintenance)
Yaw system		
Type/Design	\	Motor-driven/Four-stage planetary gear reducer
Yaw brake	\	Hydraulic brake
Control system and lightning	g prote	ection
Туре	\	PLC control system
Lightning protection design standard	\	IEC61400/24-2010 \ IEC62305-2010 standards
Lightning protection strategy	\	Integrated lightning protection system for the turbine (GL certification standards)
Tower		
Туре	\	Steel tower
Hub height	m	86/100/110 (project specific)

- 1. Generator cooling system
- 2. Wind sensors
- 3. Hoist
- 4. Yaw system
- 5. Nacelle base
- 6. Nacelle cover
- 7. Generator stator
- 8. Generator rotor
- 9. Hub
- 10. Blade
- 11. Pitch system
- 12. LiDAR

